



0000157041

BEFORE THE ARIZONA CORPORATION COMMISSION

RECEIVED

2014 OCT 28 P 3:35

ARIZONA CORPORATION COMMISSION  
DOCKET CONTROL

ORIGINAL

**COMMISSIONERS**

BOB STUMP, Chairman  
GARY PIERCE  
BRENDA BURNS  
BOB BURNS  
SUSAN BITTER SMITH

IN THE MATTER OF THE APPLICATION  
OF ARIZONA WINDSONG REALTY, INC.  
AN ARIZONA CORPORATION, FOR A  
DETERMINATION OF THE FAIR VALUE  
OF ITS UTILITY PLANT AND PROPERTY  
AND FOR ADJUSTMENTS TO ITS RATES  
AND CHARGES FOR UTILITY SERVICE  
FURNISHED BY ITS EASTERN GROUP  
AND FOR CERTAIN RELATED APPROVALS.

Docket No. W-02250A-14-0028

**NOTICE OF FILING  
BACKFLOW PREVENTION TARIFF  
FOR ARIZONA WINDSONG  
REALTY, INC.**

In Compliance with Decision No. 74597 (July 30, 2014) Arizona Windsong Realty, Inc.,  
through undersigned counsel, files its Backflow Prevention Tariff.

RESPECTFULLY SUBMITTED this 28<sup>th</sup> day of October, 2014.

ROSHKA DEWULF & PATTEN, PLC

By

Timothy J. Sabo  
One Arizona Center  
400 East Van Buren Street, Suite 800  
Phoenix, Arizona 85004

Attorney for Arizona Windsong Realty, Inc.

Original + 13 copies of the foregoing  
filed this 28<sup>th</sup> day of October 2014, with:

Docket Control  
Arizona Corporation Commission  
1200 West Washington  
Phoenix, Arizona 85007

Arizona Corporation Commission

**DOCKETED**

OCT 28 2014

DOCKETED BY

**ROSHKA DEWULF & PATTEN, PLC**  
ONE ARIZONA CENTER  
400 EAST VAN BUREN STREET - SUITE 800  
PHOENIX, ARIZONA 85004  
TELEPHONE NO 602-256-6100  
FACSIMILE 602-256-6800

1 Copies of the foregoing hand-delivered/mailed  
this 28<sup>th</sup> day of October 2014, to:

2 Lyn A. Farmer, Esq.  
3 Chief Administrative Law Judge  
4 Hearing Division  
5 Arizona Corporation Commission  
6 1200 West Washington  
7 Phoenix, Arizona 85007

8 Janice Alward, Esq.  
9 Chief Counsel, Legal Division  
10 Arizona Corporation Commission  
11 1200 West Washington  
12 Phoenix, Arizona 85007

13 Steven Olea, Director  
14 Utilities Division  
15 Arizona Corporation Commission  
16 1200 West Washington  
17 Phoenix, Arizona 85007

18 Lillie Paulsell  
19 Arizona Windsong Water Company  
20 PO Box 261  
21 Sanders, Arizona 86512

22 By *Jackie M. Howard*

## **CROSS-CONNECTION OR BACKFLOW TARIFF**

### **PURPOSE:**

The purpose of this tariff is to protect Arizona Windsong Water Co. ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

### **REQUIREMENTS:**

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

---

**\*\*FOR OFFICIAL USE ONLY\*\***

Effective Date: \_\_\_\_\_

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
  - a. assembly identification number and description;
  - b. location
  - c. date(s) of test(s);
  - d. description of repairs and recommendations for repairs made by tester;  
and
  - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

---

**\*\*FOR OFFICIAL USE ONLY\*\***

Effective Date: \_\_\_\_\_